PART 1 - GENERAL

1.1 SUMMARY

A. This Section includes the following:
   1. Interior gypsum wallboard.

1.2 QUALITY ASSURANCE

A. Fire-Test-Response Characteristics: For gypsum board assemblies with fire-resistance ratings, provide materials and construction identical to those tested in assembly indicated according to UBC Standard 7-1 (based on ASTM E 119-83) by an independent testing and inspecting agency acceptable to authorities having jurisdiction.
   1. Fire-Resistance-Rated Assemblies: Indicated by design designations from UL's "Fire Resistance Directory."
   2. Provide sound-attenuation blankets with the fire-test-response characteristics specified in this Section as determined by testing identical products per test method indicated below by UL or another testing and inspecting agency acceptable to authorities having jurisdiction. Identify materials with appropriate markings of applicable testing and inspecting agency.
      a. Surface-Burning Characteristics: UBC Standard 8-1 (based on ASTM E 84-84).
   3. Deflection and Firestop Track: Top runner provided in fire-resistance-rated assemblies indicated is labeled and listed by UL, Warnock Hersey, or another testing and inspecting agency acceptable to authorities having jurisdiction.

B. Sound Transmission Characteristics: For gypsum board assemblies with STC ratings, provide materials and construction identical to those tested in assembly indicated according to ASTM E 90 and classified according to ASTM E 413 by a qualified independent testing agency.

PART 2 - PRODUCTS

2.1 MATERIALS

A. As required by Design/Builder.

B. Impact-resistant board as required by Design/Builder.

C. Water resistant board as required by location and code.

PART 3 - EXECUTION

3.1 GENERAL

A. As required by Design/Builder and manufacturer.

END OF SECTION